

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.



Lebanon Water Works Co. Water Quality Report 2024

For previous reports include year.
Example: tapwaterinfo.com/2023/lebanon

Water System ID: KY0780241

Manager: Daren Thompson

CCR Contact: Daren Thompson

Phone: 270-692-2491

Mailing address:

120 S. Proctor Knott Avenue

Lebanon, KY 40033

Meeting location and time:

120 S. Proctor Knott Avenue

1st Monday after the 10th each month at 5:00 PM

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock

operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health

Source Information:
Lebanon Water Company treats water and also purchases some water from Campbellsville. The water is blended within the distribution system. Complete Source Water Assessment Plans are available for review at the respective water systems.

Lebanon Water Works treats surface water from the Rolling Fork River and Fagan Branch Reservoir. An analysis of the overall susceptibility to contamination for these sources indicates that this susceptibility is generally moderate. Areas of high concern for the Rolling Fork River consist of underground storage tanks, an active landfill, row crops, and bridges and culverts.

The areas of high concern at Fagan Branch Reservoir consist of row crops and the possibility for a potential chemical spill, underground storage tanks, and vehicle accidents causing the spilling of hazardous materials. Campbellsville Municipal Water System treats surface water from Green River reservoir and City Reservoir in Taylor County. An analysis of the overall susceptibility to contamination indicates that this susceptibility is generally low. The concern for the Green River Reservoir is pollution from row crops, roads, forestland, hay fields, and pastureland presenting a long-term threat to pollution. The City Reservoir is more susceptible to contamination from within its protection zone due to the lower water flow in the stream, larger number of contamination sources, and location within the city of Campbellsville.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can

be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information about Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Service Line Inventory Information:

To address lead in drinking water, EPA requires that all community water systems develop and maintain an inventory of service line materials. We have completed a service line inventory (SLI) and it is available for review at our office or our website at lebanonwaterworks.com.

Lead Sample Results Availability Information:

We are required to periodically sample water from customer taps to determine lead and copper levels. EPA sets the lead action level at 0.015 mg/L (15 ppb). For a water system to be in compliance, at least 90% of tap water samples must have lead levels below this limit. This report contains the 90th percentile and range of our most recent sampling. The individual results for each location sampled can be reviewed at our office.

We are only required to test for some contaminants periodically, so the results listed in this report may not be from the previous year. Only detected contaminants are included in this report. For a list of all contaminants we test for please contact us. Copies of this report are available upon request by contacting our office.

Regulated Contaminant Test Results								Lebanon Water Company	
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination		
Barium [1010] (ppm)	2	2	0.027	0.027 to 0.027	Feb-24	No	Drilling wastes; metal refineries; erosion of natural deposits		
Fluoride [1025] (ppm)	4	4	0.54	0.54 to 0.54	Feb-24	No	Water additive which promotes strong teeth		
Disinfectants/Disinfection Byproducts and Precursors									
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	2.9 (lowest average)	1.44 to 5.90 (monthly ratios)	2024	No	Naturally present in environment.		
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.									
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.22 (highest average)	0.56 to 1.83	2024	No	Water additive used to control microbes.		
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	38 (high site average)	15 to 41 (range of individual sites)	2024	No	Byproduct of drinking water disinfection		
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	42 (high site average)	11 to 68 (range of individual sites)	2024	No	Byproduct of drinking water disinfection.		
Household Plumbing Contaminants									
Copper (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.036 (90 th percentile)	0 to 0.048	Aug-22	No	Corrosion of household plumbing systems		
Lead (ppb) Round 1 sites exceeding action level 0	AL = 15	0	2 (90 th percentile)	0 to 3	Aug-22	No	Corrosion of household plumbing systems		
Other Constituents									
Turbidity (NTU) TT * Representative samples	Allowable Levels		Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity			
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.079	100	No	Soil runoff			
Fluoride (added for dental health)			Average	Range of Detection					
			0.7	0.62 to 0.85					

Secondary contaminants do not have a direct impact on the health of consumers. They are being included to provide additional information about the quality of the water.

Secondary Contaminant	Maximum Allowable Level	Report Level	Range of Detection	Date of Sample
Aluminum	0.05 to 0.2 mg/l	0.04	0.04 to 0.04	Feb-24
Chloride	250 mg/l	12.8	12.8 to 12.8	Feb-24
Corrosivity	Noncorrosive	-1.04	-1.04 to -1.04	Feb-24
Fluoride	2.0 mg/l	0.61	0.61 to 0.61	Feb-24
pH	6.5 to 8.5	7.19	7.19 to 7.19	Feb-24
Sulfate	250 mg/l	23.3	23.3 to 23.3	Feb-24
Total Dissolved Solids	500 mg/l	168	168 to 168	Feb-24

Regulated Contaminant Test Results								Campbellsville Water and Sewer System			
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination				
Barium [1010] (ppm)	2	2	0.02	0.02 to 0.02	Jun-24	No	Drilling wastes; metal refineries; erosion of natural deposits				
Fluoride [1025] (ppm)	4	4	0.78	0.78 to 0.78	Jun-24	No	Water additive which promotes strong teeth				
Nitrate [1040] (ppm)	10	10	0.1	0.1 to 0.1	Aug-24	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits				
Disinfectants/Disinfection Byproducts and Precursors											
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.26 (lowest average)	0.98 to 1.56 (monthly ratios)	2024	No	Naturally present in environment.				
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.											
Other Constituents											
Turbidity (NTU) TT * Representative samples	Allowable Levels		Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity					
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.2	100	No	Soil runoff					
Fluoride (added for dental health)					Average	Range of Detection					
					0.8	0.64 to 0.98					